Appendix B Communication Protocol

SX2000 series inverter provides Rs232 / RS 485 communication interface, and support the Modbus communication protocol. Users can be achieved by computing machine or PLC central control, through the communication protocol set inverter running commands, modify or read function code parameters, read the inverter working condition and fault information, etc.

1, The agreement content

The serial communication protocol defines the serial communication transmission of information content and format.Including: host polling or wide planting format;Host encoding method, the content includes: the function of the required action code, data transmission and error checking, etc.From the ring of machine should be used is the same structure, content including: action confirmation, return the data and error checking, etc.If there was an error in receiving information from a machine, or cannot achieve the requirements of the host, it will organize a fault feedback information in response to the host.

2, Application methods

Application mode inverter with RS232 / RS485 bus access to the "from" single main PC/PLC control network.

3, Bus structure

- (1) The interface way RS232 / RS485 interface hardware
- (2) Asynchronous serial transmission mode, half-duplex transmission mode. At the same time the host and the only one to send data from the machine and the other can only receive data. Data in the process of serial asynchronous communication, the form of a message, a frame of a frame to send
- (3)Topological structure from single host machine system. From the machine address set in the range of 1 \sim 247, 0 for broadcast communication address. In the network from the machine address must be unique.

4, Protocol Description

SX2000 series inverter is a kind of asynchronus serial port communication protocol of master-slave Modbus communication protocol, the network has only one equipment (host) to establish agreement (called "query/command"). Other equipment (machine) can only by providing data response of the main machine "query/command", or "query/command" according to the host to make the corresponding action. Host in this refers to the personal computer (PC), industrial control equipment or programmable logic controller (PLC), etc, from machine refers to SX2000 Inverter. The host can communicate to a separate from the machine, also can to all under a broadcast information from machine release. For access to the host alone "query/command", from the machine to return to a information (called response), for radio host information, from the machine without feedback response to the host.

5, Communications data structure

Communication data structure SX2000 series inverter of the Modbus protocol communication data format is as follows: using the RTU mode, messages are sent at least begin with 3.5 characters

pause time interval.

In network wave rate under varied characters of the time, this is the most easy to implement (below T1, T2, T3, T4). Transmission equipment is the first domain address.

The transmission character of you can use is the hex 0...9, A...F.Continuously detect network bus network facilities, including pause interval of time. When the first domain (domain) to receive, every equipment decoding to determine whether to own. After the last transmission character, a pause at least 3.5 characters time calibration for the end of the message. A new message can be started after the pause.

The entire message frame must be as a continuous flow of transmission. If the time frame to complete more than 1.5 characters before pause time, receiving equipment will refresh incomplete message and assume that the next byte is a new message the address of the domain. Likewise, if a new message in less than 3.5 characters of time and then a message before, receiving equipment will think it is a continuation of the previous message. This will result in an error, because in the final CRC field value can't be right.

RTU frame format:

The frame header START	3.5 characters	
Slave address ADR	Communication address: 1~247	
command code CMD	03: Read the machine parameters; 06: write the machine parameters	
Date content DATA (N-1		
Data content DATA (N-2	Information content: Function code parameter address, function code number of parameters, function code parameter values, etc	
Data contentDATA0		
high-order position of CRC CHK	estimated value: CRC value	
low-order position of CRC CHK	estimated value: CRC value	
END	3.5 characters'time	

CMD(Command instruction)and DATA(the description of data word) command code:03H,read N word(Word)(Can read the most words of 12)For example,From the machine address of 01 inverter startup F105 continuous read for two consecutive values

The host command information

ADR	01H	
CMD	03H	
high-order position of the starting address	F1H	
low-order position of the starting address	05H	
high-order position of register	00H	
low-order position of register	02H	
low-order position of CRC CHK	- Wait to calculate the CRC CHK values	
high-order position of CRC CHK		

ADR	01H	
CMD	03H	
high-order position of bytes	00H	
low-order position of bytes	04H	
Data high-order position of F002H	00Н	
Data low-order position of F002H	00Н	
Data high-order position of F003H	00Н	
Data low-order position of F003H	01H	
low-order position of CRC CHK	Wait to calculate the CRC CHK values	
high-order position of CRC CHK	wait to calculate the CRC CHK values	

Set PD.05 to 1:

ADR	01H

CMD	03H	
The number of bytes	04H	
Data high-order position of F002H	00Н	
Data low-order position of F002H	00H	
Data high-order position of F003H	00Н	
Data low-order position of F003H	01H	
low-order position of CRC CHK	Wait to calculate the CRC CHK values	
high-order position of CRC CHK	wait to calculate the CRC CRK values	

The command code:06H write a $word(Word)For\ example, write\ 000(BB8H)to\ slave\ machine.$

Address 05H inverter's F00AH address.

The host command information

ADR	05H	
CMD	06H	
high-order position of data address	F0H	
low-order position of data address	0AH	
high-order position of information content	0BH	
low-order position of information content	B8H	
low-order position of CRC CHK	Wait to calculate the CRC CHK values	
high-order position of CRC CHK	valit to calculate the CRC CRK values	

In response to information from the slave machine

ADR	02H
CMD	06H
high-order position of data address	F0H
low-order position of data address	0AH
high-order position of information content	13H

low-order position of information content	88H	
low-order position of CRC CHK	Wait to calculate the CRC CHK values	
high-order position of CRC CHK		

Check way:—CRC Check way:CRC(Cyclical Redundancy Check) use RTU frame format, The message includes error detection field based on the method of CRC .CRC domain test the whole content of a message. CRC domain is two bytes, contains a 16-bit binary values.it is calculated by the transmission equipment, added to the message. receive messages the device recalculate. And compared with receives the CRC in the domain of value, if the two CRC value is not equal, then there is an error in transmission.

CRC is saved in 0xFFFF,Then call a process to continuous 8-bit bytes of the message and the values in the current register for processing.Only 8 bit data in each character of CRC is effective,Starting bit and stopping bit and parity bits are invalid.

In the process of CRC,Each of the eight characters are separate and dissimilar or register contents(XOR),The results move to the least significant bit direction, set the most significant bit to 0. LSB is extracted to test,if set LSB to 1,Register and preset value dissimilarity or alone,if set LSB to 0, is not to.The whole process will repeat 8 times.when the last time (the eighth time) is completed,next 8-bit bytes and separate and register under the current value of the alien or.The values in the final register,Is all bytes in the message is executed after the CRC value.

When CRC added to the messages .The low byte to join first and then high byte.CRC Simple function is as follows:

unsigned int crc_cal_value(unsigned char *data_value,unsigned char data_length) {

```
int i;
unsigned int crc_value=0xffff;
while(data_length--)
{
crc_value^=*data_value++;
for(i=0;i<8;i++)
{
If(crc_value&0x0001)
crc_value=(crc_value>>1)^0xa001;
    else
crc_value=crc_value>>1;
    }
}
Return(crc_value);
}
```

Address definition of communication parameters

This part is the content of the communication, used to control the operation of the inverter, inverter status and related parameters setting. Read and write functional code parameter (some function code which can not be changed, only for the use of manufacturers or monitoring): function code parameter address label rules:

By function block number and the label for the parameter address representation rules .High byte: $F0\sim FF(P group), A0\sim AF(C group), 70\sim 7F(D group)low byte: 00\sim FF$

Such as:P3.12,The address is expressed as F30C; attention: PF group:Neither read the parameters, and do not change parameters;Group D group: only can read, do not change the parameters.

When some parameters in inverter is in operation, do not change; Some parameters of the inverter in any state, cannot be changed; Change function code parameters, but also pay attention to the range of parameters, units, and related instructions.

In addition, because the EEPROM is stored frequently, the service life of the block can reduce the the life of the block EPROM, so some function code under the mode of communication, do not need to be stored, just change the value of RAM.If it is P group of parameters, in order to realize the function, as long as putting this function code address high F into 0 can be achieved.If it is C group of parameters, in order to realize the function, as long as putting the function code the address of high A into 4 can be achieved. Corresponding function codes are shown as the following address: the high byte: 00 \sim 0F (P group), 40 \sim 4F(group B) low byte: 00 to FF

Such as:

Function code P3.12 is not stored in the EEPROM, The address is expressed as 030C; Function code C0-05 is not stored in the EEPROM, The address is expressed as 4005; The address representation can only do writing RAM, can't do reading action, when reading, it is invalid address. For all the parameters, can also use the command code 7H to implement this function.

Stopping/starting parameters:

Parameter address	Parameter description
1000	Communication Setting value (-10000~10000) (decimal system)
1001	Operating frequency
1002	Bus voltage
1003	output voltage
1004	current output
1005	output power
1006	output torque
1007	running velocity
1008	S Input Flag
1009	M01 output Flag
100A	FIV voltage
100B	FIC voltage
100C	Reserved
100D	count value input
100E	The length of the input
100F	The load speed

PID setting
PID feedback
PLC steps
PULSE the input pulse frequency,unit 0.01kHz
Reserved
The remaining running time
FIV before correction voltage
FIC before correction voltage
Reserved
Linear velocity
the current access to electricity time
the current running time
PULSE input pulse frequency,unit 1Hz
Communication Setting value
Reserved
The main frequency X show
Auxiliary frequency Y show

attention:

Communication setting value is relative percentage, 10000 corresponds to 100.00% and - 10000-100.00%. The frequency of dimensional data, the percentage is relative to the percentage of maximum frequency (P0.12); Counter rotating torque dimensional data, the percentage is P2.10.

Control command input to the inverter:(write-only)

The command word address	Command function
2000	0001:Running forward
	0002:Reverse running
	0003:normal inching turning
	0004:Reversal point move
	0005:Free downtime
	0006:Slowing down
	0007:Failure reset

Read the inverter state: (read-only)

Status word address	Status word function		
	0001:Running forward		
3000	0002:Reverse running		
	0003:closing down		

Parameters lock password check: (if return for 8888H,it indicates that the

password check through)

Password address	The content of the input password		
1F00	****		
Command address	Command content		
	BIT0:(reserved) BIT1:(reserved)		
2001	BIT2:RA-RB-RC output control BIT3:reserved		
	BIT4:MO1 output control		

Analog output FOV control: (write-only)

Command address	Command content
2002	0~7FFF represent 0%~100%

Analog output control:(Reserved)

Command address	Command content
2003	0~7FFFrepresent 0%~100%

PULSE (PULSE) output control: (write -only)

Command address	Command content	
2004	0~7FFFrepresent 0%~100%	

Inverter fault description:

Inverter fault address	Inverter fault information		
8000	0000:failure-free 0001:reserve 0002:Accelerate over current 0003:Slow down over current 0005:Accelerate over the voltage 0006:Slow down over voltage 0006:Slow down over voltage 0007:Constant speed over voltage 0008:Buffer resistance overload fault 0009:Under-voltage fault 000A:The inverter overload 000B:Motor overload 000C:reserved 000D:The output phase 000E:Module is overheating 00F:External fault 0010:Abnormal communication 0011:Abnormal contactor 0012:Current detection fault 0013:Motor tuning fault 0014:reserved 0015:Abnormal parameters, reading and writing 0016:Inverter hardware failure		

	0017:Motor for short circuit fault
	0018:reserved
	0019:reserved
	001A:Running time reached
	001B: reserved
	001C: reserved
	001D: Accumulative power-on time reached
	001E:Load becoming 0
8000	001F:PID feedback lost during running
0000	0028:With-wave current limit fault
	0029:Motor switchover fault during running
	002A: Too large speed deviation
	002B: Motor over-speed
	002D:Motor overheat
	005A:Encoder line number setting error
	005B:Don't connect the encoder
	005C:Initial position fault
	005E:Speed feedback error

Communication failures address	Fault feature description	
8001	0000:failure-free 0001:Password mistake 0002:The command code error 0003:CRC Checking error 0004:Invalid address 0005:Invalid parameter 0006:correcting parameter is invalid 0007:System is locked 0008:Block is EEPROM operation	

FD group Communication parameters show

	Baud rate	The factory value	0005
PD.00	setting range	units' digit:MODUB 0:300BPS 1:600BPS 2:1200BPS 3:2400BPS 4:4800BPS 5:9600BPS 6:19200BPS 7:38400BPS 8:57600BPS 9:115200BPS	S Baud rate

This parameter is used to set data transfer rate between the PC and inverter. Notice that setting the baud rate of upper machine and inverter must agree, otherwise, the communication can't carry on. The faster the baud rate, the greater the communication.

	The data format	The factory value	3
PD.01	setting range	0:No check:The da 1:Even-parity:The da 2:Odd parity check format<8,0,1> 3:No check:The da	data format<8,E,1> :The data

PC and data format set by the inverter must agree, otherwise, the communication can't carry on.

PD.02	The machine address	The factory value	1
	setting range	1~247, 0 is the b	roadcast address

When the machine address set to 0, namely for the broadcast address, realize PC broadcasting functions.

The machine address has uniqueness (except the broadcast address), which is to achieve the basis of upper machine and inverter peer-to-peer communications.

PD.03	Response latency	The factory value	2ms
PD.03	setting range	0~2	0ms

Response latency: refers to the inverter data to accept the end up to a upper machine to send data in the middle of the interval of time. If the response time delay is less than the system processing time, the response time delay will be subject to system processing time, processing time, such as response time delay is longer than system after processing the data, the system will delay waiting, until the response delay time to up to a upper machine to send data.

PD.04	Communication timeout	The factory value	0
	setting range	0.0 s (invalid) 0.1~60.0s	

When the function code is set to $0.0~\mbox{s}$, communication timeout parameter is invalid.

When the function code set to valid values, if a communication and the interval time of the next communication beyond the communication timeout, system will be submitted to the communication failure error (CE). Usually, it is set into is invalid. If, in the continuous communication system parameter set the time, you

can monitor the communication status.

PD.05	Communication protocol selection	The factory value	1
	setting range	Non standard Modbus protocol The standard Modbus protocol	

PD.05=1:choose the standard Modbus protocol

PD.05=0: when reading command ,Returns number of bytes from the machine is a byte more than the standard Modbus protocol, detailed in this agreement

5 Communication data structures.

PD.06	Read the current resolution	The factory value	1
	setting range	0: 0.01A 1: 0.1A	

Used to determine the communication while reading the output current, current value of the output units.